

**Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu**

**The Principal
Heritage School
Sector-D-Extension
Sainik Colony, Tehsil Bahu
District Jammu**

No: JDF&ES/FP/ 6329

Dated: 30.12.2021

Sub: Fire Safety Certificate.

Ref: Your online application submission dated 30.11.2020.

Dear Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed Sprinklers, Hydrants, Smoke Detectors, Hose Reel Hoses, Fire Pumps and First Aid Fire Extinguishers of different make and capacity in their school premises, besides two underground water storage tanks of 75 KL capacities each respectively. The school is 06 Km away from Fire & Emergency Station Gangyal and is approachable for fire tenders in case of any emergency. As such, this office has no objection for running the school subject to adopt the following fire safety precautionary measures in letter and spirit:-

1. All exists/staircase should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
2. Hose Cabinet should be installed near each Fire Hydrant Point.
3. Fire Pump should be on Automatic Pressurized Mode.
4. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/ operating of fire fighting system installed in the school building. The management shall intimate this office in writing after each quarter that the fire fighting equipments installed in the school are functioning.
5. No Hazardous material should be kept inside or outside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, the clearance will be treated withdrawn/cancelled.
6. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
7. The corridor of the building shall not be used for any kind of storage.
8. The management shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
9. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
10. At present school is having three blocks in which one is triple storey with basement, second is four storey and third is double storey. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department.
11. The validity of this clearance shall remain in force for one year and same needs to be renewed after checking of fire fighting system installed in the school.

Yours sincerely



**Joint Director
Fire & Emergency Services
Jammu Range, Jammu**

